

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 284

Date : 23/01/2023

It is certified that an inspection team headed by Sudhu Lal
(Name of Officers
with designation) from Junior Engineer, Hajipur (Name of
Department/Office) inspected the Surajdeo Memorial School
Surajdeo Nagar, Bagmali, Hajipur Vaishali (Name & Address of
the School) on 12-01-2023 and found that the Surajdeo
Memorial School. (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of One Year

Signature with Seal : 2-TH 24/1/23
Name : Executive Engineer
P.H. Division, Hajipur
(Vaishali)
Designation : _____

To
The Principal
Surajdeo Memorial School
Surajdeo Nagar Bagmali, Hajipur (VLL)
(Name & Address of the Institution)

Let No! - 15 /12/01/2022

**Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report**

District Name: - Vaishali

Division Name:- Hajipur

Month:-Jan. - 2023

SL. No.	Block	Panchyat	Village	Name of Habitation	Location of Source	Parameters																Report handed over to beneficiary or not	Demarkation of contaminated sources	Data online or not	Remarks
						pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	AL	Fe	NO ₃	SO ₄	F	As	Total Coli					
1	Hajipur	Nagar Parishad	Bagmali	Bagmali	Surajdeo Memorial School	6.8	1	150	98	Chemical not available				20	Chemical not available				0.1						
Acceptable limit						6.5-8.5	1.0	-	500	200	75	23.04	250	200	0.3	45	200	1.0	0.01						
Permissible Limit* in absence of alternate source						NR	5.0	-	2000	600	200	100	1000	600	1.0	NR	400	1.5	NR	**					
						-	NTU	m/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l							

Note: (i) Drinking Water Specification Second Revision -IS:10500:2012., (ii) BDL means Below Detection Limit., (iii) NR means no relaxation.

** (a) Throughout any year, 95% of the samples should not contain coliform organisms in 100ml, (b) No sample should contain more than 10 coliform organisms per 100ml, (c) Coliform organisms should not be detected in 100ml of any two consecutive samples.

Lab Asissant
PH Division Hajipur

Shobha kr.
12/01/2023
Chemist
PH Division Hajipur

Shobini
12/01/2023
Assistant Engineer
PH Division Hajipur

2/12/23
12/01/23
Executive Engineer
PH Division Hajipur

To